



Bid Questions and Answers Report

Date & Time: 10/25/2017 8:24:53 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3658

Project: 219722-4-52-01

Letting Date: 10/25/2017

Location: CENTRAL OFFICE

Description: SR 263 (CAPITAL CIRCLE NW) AND SR 8 (I-10)

Question:	19568: The irrigation detail on sheet LD-68 calls for a Double Check Backflow preventer while Note 17 on sheet LD-70 calls for a Reduced Pressure Backflow preventer. Which one is preferred? Thank you.	Posted:	9/15/2017 6:20:52 AM
Answer:	Per City of Tallahassee code, a reduced pressure model must be used.	Status:	ANSWER PUBLISHED
		Posted:	9/18/2017 3:43:37 PM
Question:	19577: The Tree Bubbler on LD-66 calls for Hunter Bubblers while the material legend on LD-69 calls for Rainbird Series Bubblers. Which is preferred? Thank you.	Posted:	9/15/2017 1:06:33 PM
Answer:	Hunter PCB in equivalent GPM to the what the legend calls out for rainbird bubblers. (for example legend calls for Rainbird 1401 (.25 GPM) use a Hunter PCB-25)	Status:	ANSWER PUBLISHED
		Posted:	9/22/2017 4:49:47 PM
Question:	19608: Considering the traffic on this project and inside lane closures, can this landscape project be built at night M-TH 6:30pm-6:30am?	Posted:	9/20/2017 2:31:30 PM
Answer:	Revision forthcoming with Lane Closure modifications	Status:	ANSWER PUBLISHED
		Posted:	9/21/2017 4:26:17 PM
Question:	19609: Page 14 of the specifications SUBARTICLE 7-2.2 states that the Generic Permit for Stormwater Discharge large and small construction activities permit applies to the contract. Plan sheet LD-73 (SWPPP) note 2-D states there are no Federal, State or Local permits required? Please clarify if this permit is needed or not.	Posted:	9/20/2017 2:51:50 PM

Answer:	Yes, the contractor is responsible for obtaining the Generic Permit for Stormwater Discharge large and small construction activities. This permit is the NPDES permit the contractor is required to obtain on his behalf. The Department does not get them. The landscaping project by itself did not require any other permits.	Status:	ANSWER PUBLISHED
		Posted:	9/21/2017 4:27:22 PM